



## **ADDENDUM # 2**

### **Whiting Lane Elementary School Main Entrance Security Renovation**

### **BID # 200042**

**June 12, 2020**

**Dear Vendors:**

**The Contract Bidding Documents pursuant to Bid # 200042 are hereby revised as follows. Bidders shall acknowledge this addendum in their bid response:**

Whiting Lane Elementary School – Pre Bid Conference Questions:

1. Made a change on two drawings. See attached. Wall and door change into the office area from the main lobby.
2. Ceiling Panels – Per specifications: Armstrong Cirrus Beveled Tegular Edge #539. 24"x24". Use existing panels from area of construction to replace damaged panels or cut panels in corridor.

Attachments: Addendum 2 Drawings

Thank you,

Rick Hyman

Buyer

Cc: Bill Phibbs, Capital Projects Manager

J. Kirk Bostwick, AIA Bostwick Architects LLC

**END OF ADDENDUM # 2**